


NOTES:

1. WARNING TAPE TO BE INSTALLED 12" BELOW FINAL GRADE IF UNDER NATURAL SOIL OR 18" BELOW FINAL GRADE IF UNDER ASPHALT OR CONCRETE.
2. CONTACT CEC FOR INSPECTION OF CONDUIT INSTALLATION PRIOR TO BACKFILLING TRENCH
3. COMPACTED BACKFILL 95% MODIFIED PROCTOR DENSITY
4. SIZE AND QUANTITY OF CONDUIT AS SPECIFIED ON CONDUIT PLAN.
5. CONDUIT SHALL BE ELECTRICAL GRADE SHEDULE 40 PVC OF SIZE SPECIFIED
6. A PULL STRING SHALL BE INSTALLED IN EACH CONDUIT. REFER TO CONDUIT EXIT GUIDE DRAWING FOR DETAILS

ELBOW DESCRIPTION	RADIUS
1" - 90° OR 45°	18"
2.5" - 90° OR 45°	36"
3" - 90° OR 45°	36"
4" - 90° OR 45°	36"
6" - 90° OR 45°	48"

 <p>Coastal Electric Cooperative Your Touchstone Energy® Partner</p>	TRENCH DETAIL		REVISED
	DRAWN BY: CJH	APPROVED BY: JWM	
	DATE: 6-7-06	SCALE: NTS	